# **DIN W48×H24mm Small Size Digital Panel Meter**


### Features

- Max. display: 1999
- Auto Zero function and Hold function
- 7-segment LED display
- Power supply: 5VDC, 12-24VDC

Please read "Caution for your safety" in operation manual before using.


# Ordering Information

#### O DC VOLTAGE METER / DC CURRENT METER



×M4N series is to measure DC only. AC voltage and AC current is not available to be measured. \*Measuring range for direct connection is max. 200VDC, max. DC200mA.

### **O DIGITAL SCALING METER**



※1-5VDC measuring input is optional.

If there is no additional order, its factory default is DC4-20mA.





# Specifications

					Photoelectric Sensors		
Model		M4N-DV-	M4N-DA-	M4N-DI-	(B)		
Measurement input		DC voltage	DC current	DC4-20mA	Fiber Optic Sensors		
Power supply		5VDC, 12-24VDC			(C)		
Allowable voltage range		90 to 110% of rated voltage			Door/Area Sensors		
Power consumption		2W			(D)		
Display method		7-segment LED display (red) (character height: 10mm)			Proximity Sensors		
Max. display range		Max. 1999			(E) Pressure Sensors (F) Rotary Encoders		
Display accuracy		F·S ±0.2% rdg ±1-digit					
Sampling period		300ms					
A/D switching method		Dual integral method					
Response time		Approx. 2sec (0 to 1999)			(G) Connectors/ Connector Cables/		
Max. allowable input		150% of measurement input range			Sensor Distribution Boxes/ Sockets		
Sampling time		2.5 times/sec			(H) Temperature		
Insulation resistance		Over 100MΩ (at 500VDC megger)			Controllers		
Dielectric strength		2000VAC 50/60Hz for 1 min			(I) SSRs / Power Controllers		
Noise immunity		$\pm 100V$ the square wave noise (pulse width: 1µs) by the noise simulator			Controllers		
Vibration	Mechanical	0.75mm amplitude at frequency of 10 to 55Hz (for 1 min) in each X, Y, Z direction for 1 hour			(J) Counters		
	Malfunction	0.5mm amplitude at frquency of 10 to 55Hz (for 1 min) in each X, Y, Z direction for 10 min					
Shock	Mechanical	300m/s <sup>2</sup> (approx. 30G) in e	ach X, Y, Z direction for 3 times		(K) Timers		
	Malfunction	100m/s² (approx. 10G) in e	m/s <sup>2</sup> (approx. 10G) in each X, Y, Z direction for 3 times				
Environment	Ambient temperature	-10 to 50°C, storage: -20 to	60°C		(L) Panel Meters (M)		
	Ambient humidity	35 to 85%RH, storage: 35 t	to 95%RH				
Unit weight		Approx. 44g			Tacho / Speed / Pulse Meters		

XEnvironment resistance is rated at no freezing or condensation.

# Connection





※1: 5VDC, 12-24VDC

※In case of changing position of decimal point, disconnect switching pattern point on PCB and connect terminal contact according point to be changed.

\*Socket pin 9, NC terminal, is not connected at inside.

Speed / Pulse Meters (N) Display Units

(A)

(O) Sensor Controllers

(P) Switching Mode Power Supplies

(Q) Stepper Motors & Drivers & Controllers

& Controllers (R)

(R) Graphic/ Logic Panels

(S) Field Network Devices


-----

(T) Software

### Dimensions


Bracket

(unit: mm)




# Connections

### © DC volt meter connection



(Fig. 1) Measuring input (V1) is under 200VDC




(Fig. 2) Measuring input (V1) is under 200VDC

XWhen the measuring voltage is over 200VDC, please select R1 and R2 in order to make V2 less than max. measuring voltage using multiplier.


$$V2 = \frac{R2}{R1+R2} \times V1 \qquad R1 > R2$$

### Scaling meter connection




%1-5VDC output of converter is sold separately.

### O DC current meter connection



(Fig. 3) Measuring current is under DC200mA



(Fig. 4) Measuring current is 50mVDC

%When the current is higher than DC200mA, please use shunt.

%Second section of shunt is DC50mV.

# Proper Usage

O Caution for selecting and using products

- Be careful customized product by requirement cannot be replaced.
- When power is applied, it may display arbitrary number, because measuring input terminal is opened. If connect Low terminal of measuring input to GND, it displays "000".
- If it indicates 1 or -1 during input signal is ON, please turn OFF the power and check the connection condition, because the input signal is too low or high.
- When measuring voltage is higher than 200VDC, please divide the voltage with multiplying resistance to make lower than 200VDC.

(Refer to the connection method of DC volt meter in the application of connections)

E.g.)Measuring 1000VDC


- As the above connection figure of DC volt meter, select the R1 value to make 200VDC on R2. (Generally R1 value will be higher than R2 value.) Order the D.P.M indicating 1000V for 300VDC.
- Select another item or use shunt for over than DC200mA of measured value.

(See the connection method of DC current for the application of using shunt.)

E.g.)In case of measuring 20ADC

- Use the shunt used for 20ADC/50mVDC and the specification
- should be ordered as M4N-DV-X 50mVDC/19.99. XOur company does not sell a shunt. Please connect our distributor to purchase the item.
- M4N series is produced for 5VDC and 12-24VDC. Therefore, before you order the item please check the model again.
- · The specification of measurement input, which is indicated in model ordering, is a standard specification, 1:1 of measurement input and processing value. The additional specifications can be customizable.
  - \* The application of M4N-DV/M4N-DA M4N - DV - 0X 10VDC / 100.0
  - M4N DA 0X DC50mA / 199.9
  - \* The application of M4N-DI
  - M4N DI 0X DC4-20mA / 100.0
- Note)If measurement input is 1-5VDC, please indicate it. Other wise, it will be produced with DC4-20mA.

 Indicating method of unit M4N is not indicated a unit on the product, therefore please indicate it in panel.



Display of decimal point

The displaying decimal point is set in the product by your order


(The prior products display the decimal point by using jump line in external connector like as connection figures.)

After purchasing the product, do not change the decimal point. If you need to change it, please connect us or distributor.

#### O Caution for connecting M4N

• In case of using both volt meter and current meter Because the connection of measurement input terminal and power terminal is not insulated, when you use volt meter and current meter by connecting one set, please provide individual power.


In case of using same power, it may damage the product.



%1: If measure higher current than measuring input range, please use a shunt. If measure higher voltage than measuring input range, please use multiplier.

XIf use a voltage measurement function meter and a current measurement function meter to a set, please use each DC power 1 individually.

- ※Power terminal and measurement input terminal are shorted inside of the product.
- It is available using several volt meters with providing one DC power. However, the potential difference between - of measurement input and - of power may cause an error.



\*Current meter cannot be used with above connection. Please provide power separately.

 Make sure to check the polarity of provided power before turn ON the power.

(If the polarity is connected reversely, internal circuit could be damaged.)

 Please check if the pin numbers are changed after connecting.

(A) Photoelectric Sensors

(B) Fiber Optic Sensors

(C) Door/Area Sensors

(D) Proximity Sensors

(E) Pressure Sensors

(F) Rotary Encoders (G)

Connectors/ Connector Cables/ Sensor Distribution Boxes/ Sockets

Temperature Controllers

(I) SSRs / Power Controllers

(J) Counters

(K) Timers

(M) Tacho / Speed / Pulse Meters

(N) Display Units

(O) Sensor Controllers

(P) Switching Mode Power Supplies

(Q) Stepper Motors

(R) Graphic/ Logic Panels

(S) Field Network Devices

(T) Software